



ENVIRONMENTAL PROTECTION LICENCE 1246

DISCHARGE WATER QUALITY MONITORING

17th April 2026

Pollutant	Unit of measure	100 percentile concentration limit	Result Point 1 (Dam 10)	Result Point 2 (Dam 1)	Exceedances
Oil & Grease	milligrams per litre	10	<5	Not discharging	No
pH	pH	6.5-8.5	7.1	Not discharging	No
Total Suspended Solids (TSS)	milligrams per litre	40	<5	Not discharging	No