



ENVIRONMENT PROTECTION LICENCE 1596

August 2022 Surface Water Quality Monitoring

LIMITS

ANALYTE	BOD	pH	Salinity	TSS
Units	mg/L	pH	µs/cm	mg/L
100 percentile concentration limit	20	6.5 – 8.5	n/a	30
Frequency of sampling	During each overflow event			
Location of sampling	Overflow weir EPA Identification Point 1			

RESULTS

DATE	BOD	pH	Salinity	TSS	Exceedance Y/N
	mg/L	pH	µs/cm	mg/L	
11/05/2022	<2	7.93	0.44	9	N