



## ENVIRONMENT PROTECTION LICENCE 1596

### FEBRUARY 2024 Surface Water Quality Monitoring

#### LIMITS

ANALYTE	BOD	pH	Salinity	TSS
Units	mg/L	pH	µs/cm	mg/L
100 percentile concentration limit	20	6.5 – 8.5	n/a	30
Frequency of sampling	During each overflow event			
Location of sampling	Overflow weir EPA Identification Point 1			

#### RESULTS

DATE	BOD	pH	Salinity	TSS	Exceedance Y/N
6/02/2024	2	8.25	0.04	102	Y
22/02/2024	<2	7.85	0.37	27	N