



ENVIRONMENT PROTECTION LICENCE 1596

AUGUST 2021 Surface Water Quality Monitoring

LIMITS

ANALYTE	BOD	pH	Salinity	TSS
Units	mg/L	pH	µs/cm	mg/L
100 percentile concentration limit	20	6.5 – 8.5	n/a	30
Frequency of sampling	During each overflow event			
Location of sampling	Overflow weir EPA Identification Point 1			

RESULTS

DATE	BOD	pH	Salinity	TSS	Exceedance Y/N
26/08/2021	3	8.38	0.67	12	N