



## ENVIRONMENT PROTECTION LICENCE 1596

### DECEMBER 2023 Surface Water Quality Monitoring

#### LIMITS

ANALYTE	BOD	pH	Salinity	TSS
Units	mg/L	pH	µs/cm	mg/L
100 percentile concentration limit	20	6.5 – 8.5	n/a	30
Frequency of sampling	During each overflow event			
Location of sampling	Overflow weir EPA Identification Point 1			

#### RESULTS

DATE	BOD	pH	Salinity	TSS	Exceedance Y/N
21/12/2023	<2	8.5	0.5	8	N