



ENVIRONMENT PROTECTION LICENCE 1596

JULY 2024 Surface Water Quality Monitoring

LIMITS

ANALYTE	BOD	pH	Salinity	TSS
Units	mg/L	pH	µs/cm	mg/L
100 percentile concentration limit	20	6.5 – 8.5	n/a	30
Frequency of sampling	During each overflow event			
Location of sampling	Overflow weir EPA Identification Point 1			

RESULTS

DATE	BOD	pH	Salinity	TSS	Exceedance Y/N
					N
2/07/2024	3	7.78	0.21	7	N
9/07/2024	3	7.58	0.28	<5	N
29/07/2024	<2	8.06	0.07	<5	N