



ENVIRONMENT PROTECTION LICENCE 1596

JUNE 2024 Surface Water Quality Monitoring

LIMITS

| ANALYTE | BOD | pH | Salinity | TSS |
|------------------------------------|---|-----------|----------|------|
| Units | mg/L | pH | µs/cm | mg/L |
| 100 percentile concentration limit | 20 | 6.5 – 8.5 | n/a | 30 |
| Frequency of sampling | During each overflow event | | | |
| Location of sampling | Overflow weir EPA Identification Point 1 | | | |

RESULTS

| DATE | BOD | pH | Salinity | TSS | Exceedance Y/N |
|------------|-----|------|----------|-----|----------------|
| | | | | | N |
| 6/06/2024 | <2 | 8.1 | 0.34 | 46 | Y |
| 13/06/2024 | <2 | 7.25 | 0.13 | 13 | N |